

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Divergent Adhesives IIc □

176 Glenwood Ln., Gray Court □, SC, United States

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, and private office, parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017); Hong Kong Air Pollution Control (VOC) Regulation.

Standard Product Application Amount: 5027 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup>; Between 0.5 – 5.0 mg/m<sup>3</sup>; Greater than/equal to 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-07654

Valid from: February 14, 2022 to September 30, 2022



A handwritten signature in black ink that reads 'Stanley Mathuram'.

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

## **Certification Addendum**

### **Divergent Adhesives IIc** □

Certification: Registration # SCS-FS-07654 | Valid from: February 14, 2022 to September 30, 2022

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

Addendum **FloorScore®**

Conformance: Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, and private office, parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017); Hong Kong Air Pollution Control (VOC) Regulation.

Standard Product Application Amount: 5027 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> ; Between 0.5 – 5.0 mg/m<sup>3</sup> ;

Products: **Adhesive:**

220 Multi-Purpose, 330 Premium Multi-Purpose, 564 PSA, 574 Modified PSA, CT 610 PSA, RC3 CTS, UV4500 Seam Sealer, Wall Base Adhesive