***SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:*

Divergent Adhesives LLC

715 North Murray Avenue, Anderson, South Carolina 29625, United States

For the following product(s):

Flooring Adhesive:
524 Pressure Sensitive Adhesive, 564 Pressure Sensitive Adhesive,
757 XT Wall Base Adhesive, RC3 CTS Adhesive

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (November 2022); Hong Kong Air Pollution Control (VOC) Regulation.

Standard Product Application Amount: 168.7 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m^3 (in compliance with CDPH/EHLB Standard Method v1.2-2017

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-20475

Valid from: July 01, 2026 to June 30, 2027

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.

Diana Kirsanova Phillips, Chief of Staff to the CEO / Chief Assurance Officer
SCS Global Services